

# CERTIFICATE

Issued to:

Applicant:

Seval Kablo Aydınlatma Cihaz ITH IHR SAN VE  
TIC A.S

Hacıyuplu Mah 3119 Sokak No 5 Uçler-Denizli  
20195 Denizli, Türkiye

Licensee:

Seval Kablo Aydınlatma Cihaz ITH IHR SAN VE  
TIC A.S

Hacıyuplu Mah 3119 Sokak No 5 Uçler-Denizli  
20195 Denizli, Türkiye

Product : Flexible cables with thermoplastic PVC insulation  
Trade name(s) : SEVAL KABLO, SK or VOIFLEX  
Type(s)/model(s) : H05VV-F

The product and any acceptable variation thereof as specified in the Annex to this certificate and the documents referred to therein.

DEKRA hereby declares that the above-mentioned product has been certified based on:

- a type test according to EN 50525-1:2011, EN 50525-1:2011/A1:2022 and EN 50525-2-11:2011
- an inspection of the factory location according to CENELEC Operational Document CIG 021
- a DEKRA certification agreement with the number 2150792


DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on 28 July 2024 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 2153349.02 REV.1

DEKRA Certification B.V.



B.T.M. Holtus  
Managing Director



Miranda Zhou  
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE  
DUTCH ACCREDITATION  
COUNCIL



**SPECIFICATION OF THE CERTIFIED PRODUCT****Product data**

Product	: Flexible cables with thermoplastic PVC insulation
Trade name(s)	: SEVAL KABLO, SK or VOIFLEX
Type(s)/model(s)	: H05VV-F
Rated voltage	: 300/500 V
Conductor	: Copper class 5
Insulation	: PVC compound of type TI 2
Sheath	: PVC compound of type TM 2

**Product data – type H05VV-F**

Tested cords	: 2x0,75 mm <sup>2</sup> (white sheathed) 5G2,5mm <sup>2</sup> (black sheathed)
Certified cords	: 2x0,75 mm <sup>2</sup> up to and including 2x2,5mm <sup>2</sup> (all sheath colours) 3x0,75 mm <sup>2</sup> up to and including 3x2,5mm <sup>2</sup> (all sheath colours) 4x0,75 mm <sup>2</sup> up to and including 4x2,5mm <sup>2</sup> (all sheath colours) 5x0,75 mm <sup>2</sup> up to and including 5x2,5mm <sup>2</sup> (all sheath colours) 3G0,75 mm <sup>2</sup> up to and including 3G2,5mm <sup>2</sup> (all sheath colours) 4G0,75 mm <sup>2</sup> up to and including 4G2,5mm <sup>2</sup> (all sheath colours) 5G0,75 mm <sup>2</sup> up to and including 5G2,5mm <sup>2</sup> (all sheath colours)

**TESTS****Test requirements**

EN 50525-1:2011  
EN 50525-1:2011/A1:2022  
EN 50525-2-11:2011

**Test result**

The test results are documented in DEKRA test file 215334900, 228891000.

**Additional information**

This certificate replaces certificate No. 2153349.02 which we hereby declare invalid.

**Conclusion**

The examination has confirmed that all requirements were met.

**Factory locations**

Seval Kablo Aydınlatma Cihaz ITH IHR SAN VE TIC A.S  
Hacıyuplu Mah 3119 Sokak No 5 Uçler-Denizli  
20195 Denizli, Türkiye

Seval Kablo Aydınlatma Cihazları İthalat ve İhracat San. ve Tic. A.S.  
Ortakçı Mahallesi Bekir Ongun Bulvarı No:7  
09679 Aydın, Türkiye